

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
8/8/2022	66556

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	8/8/2022			

Qty	Item Code	Description	Price Each	Amount
1	Emergency Labor-PB	DH469777 1 Heather Lane Media, PA 19063 Date of service 8/8/22 Technician Pat Brady Arrived on site and pump DH469777 wasn't in alarm and all meter checks were correct pulled pump for further evaluation and found that there is a clog some where in the house. I showed homeowner that there is no water coming into station from her house and I cycled the pump. Pump goes into and out of alarm and from on/off 32 seconds at 5.8 amps pump is running correctly. Plumber told her that water was filled to the top of station station is completely dry even the grass around the station. 1 Emergency Weekend/After Hours Rate Emergency Labor rate for Pat	165.00 165.00	165.00 165.00
				Total \$330.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.