

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

| Date | Invoice # |
|-----------|-----------|
| 8/12/2022 | 66626 |

| Bill To |
|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-----|-----------|----------|-------|---------|
| | Net 30 | DR | 8/12/2022 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|--------|-------------------------|--|------------------|------------------|
| 1 2 | Service/Ins Labor-DR | Replace A137674 with new Twp pump DH799241 404 Highland Avenue Media, PA 19063 Date of service 8/12/22 Technician Dylan Rearick Arrived on site, power to panel normal, meter checks indicate flooded controls. Pulled A137674 and found cracked top housing and flooded controls. Testing of motor found it had failed. Pump requires full rebuild or replacement. Went to shed and brought dh799241 back and installed in station. Tested system, job complete. Service Call & Inspection Fee < Labor Rate for Dylan Rearick | 150.00 110.00 | 150.00 220.00 |

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.