

Date	Invoice #
8/14/2022	66643

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	Jon M	8/14/2022			

Qty	Item Code	Description	Price Each	Amount
1	Emergency Labor-Jon M	Repair DH486590 141 Springton Lake Road Media, PA 19063  Date of service 8/14/22 Technician Jon McKee  Customer had an alarm that was intermittent. Customer was able to verify that it was an EONE system. Notified customer that I could check it out on Sunday, August 14th. •Arrived on site on August 14th, station was not in active alarm. Pulled the lid of the tank to check for water, dry well was dry. Station was a deeper station. Checked panel and noticed an “overpressure” light was active. Reset breakers and overpressure went away. Began taking meter readings and had good readings. Checked for voltage, voltage was good. Had the customer run water to test pump, pump ran well at 6.6 amps. Had the customer continuously run water for a duration of time to cycle the pump. Cycled the pump approximately 10 times with no issues. Station is in proper working order and no need to return at this time. Serviced August 14th.  1 Emergency 1 Labor-Jon M	165.00 165.00	165.00 165.00

All material remains the property of Site Specific Design until final payment.

**Total**

\$330.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.