

Site Specific Design, Inc.

*1704 Rockwell Road
Abington, PA 19001
215-887-3730*

Invoice

Date	Invoice #
8/16/2022	66672

Bill To Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Ship To Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063
---	---

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	8/16/2022			

Qty	Item Code	Description	Price Each	Amount
		<p>Replace DH429241 with new Twp pump DH799233</p> <p>360 Paxon Hollow Road Media, PA 19063</p> <p>Date of service 8/16/22 Technician Pat Brady</p> <p>Arrived on site and found pump DH429241 in alarm panel read over pressure and water coming out of the clean out .Performed meter readings and all readings were incorrect. Pulled pump for further evaluation and found station had a lot of paper towels and wipes . evaluated the pump and found that the motor was flooded and megged bad. Installed new upper providence pump.DH799233 , and Pump goes into and out of alarm and from on/off 32 seconds at 5.7 amps pump is running correctly</p>		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-PB	Labor rate for Pat	110.00	110.00

All material remains the property of Site Specific Design until final payment.

Total

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.