

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
8/18/2022	66698

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	8/18/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins	Replace Dh433179 with new Twp core dh799239 119 West Bishop Hollow Road Media, PA 19063 Date of service 8/18/22 Technician Dylan Rearick Arrived on site, station in alarm and running continuously. Pulled pump, motor and control housing heavily corroded, pump is steaming hot when removed. Inspected and found level sensing housing and various rubber and plastic parts melted due to extreme heat of dry run. Motor fails testing. Went to shed and installed new pump in station. Ran water from house and tested system successfully.		
2	Labor-DR	Service Call & Inspection Fee < Labor Rate for Dylan Rearick	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.