

Date	Invoice #
8/23/2022	66746

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	8/23/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH430838 1971 Kimberwick Road Media, PA 19063		
		Date of service 8/23/22 Technician Dylan Rearick		
		Power to panel good, pump does not run. meter checks indicate failed controls, pulled pump and inspected. Found corroded switches and burnt controls. Motor tests fine. Replaced parts and reinstalled in station, system operates normally.		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-DR	Labor Rate for Dylan Rearick	0.00	0.00
1	Labor-DR	Labor Rate for Dylan Rearick	110.00	110.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	0.00	0.00

All material remains the property of Site Specific Design until final payment.

**Total**

\$336.38

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.