

Date	Invoice #
8/26/2022	66791

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	8/26/2022			

Qty	Item Code	Description	Price Each	Amount
1.5	Service/Ins Labor-PB	<p>Replace DH425005 with new Twp pump DH795005 292 Steeplechase Drive Media, PA 19063</p> <p>Date of service 8/26/22 Technician Pat Brady</p> <p>Arrived on site and found pump DH425005 In high level alarm and not running.Took meter readings and they were incorrect.Pulled pump for further evaluation and found control housing bolt holes corroded through , blown capacitor on control bracket and the motor megs bad. Installed a new upper providence core DH795005 pump goes into and out of alarm and from on/off 30 seconds at 5.5 amps pump is running correctly.</p> <p>Service Call & Inspection Fee < Labor rate for Pat</p>	150.00 110.00	150.00 165.00

All material remains the property of Site Specific Design until final payment.

Total

\$315.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.