

Date	Invoice #
8/29/2022	66817

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	SM	8/29/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH506121 107 Dunns Cove Road Media, PA 19063 Date of service 8/28/22 Technician Shawn McKee Called customer and no answer left a voice message.. Customer called back said grinder is in alarm and backing up into basement. outside unit requested service for Sunday.arrived on site at 3:00pm.pump in alarm. Pulled pump and inspected find broken tabs on switches and blown controls.. also stator was in run dry. Replaced switches control an stator. Reinstalled the pump DH506121 and cycled good at 6amps at 36secs. Finished at 4:30 upper providence		
1	Emergency Labor-SM	Emergency Weekend/After Hours Rate	165.00	165.00
1.5		Emergency Labor-Shawn M	165.00	247.50
1	8203	STATOR/LINER ASSY EXTREME NC0039G01	51.8225	51.82
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	141.83	141.83

All material remains the property of Site Specific Design until final payment.

Total

\$682.53

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.