

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Invoice

Date	Invoice #
9/8/2022	66951

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 449 Old State Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	9/8/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair A254023 449 Old State Road Media, PA 19063 Date of service 9/8/22 Technician Dylan Rearick Arrived on site, power to panel and meter checks normal. Clean out pipe flooded but tank empty. Informed customer inlet pipe was clogged. Inspected pump and found corroded switches, rest of pump fine. Replaced switches and gasket and reinstalled in station,		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
2	Labor-DR	Labor Rate for Dylan Rearick	110.00	220.00
1	7090	PA1016PO1 PRESSURE SW, ON/OFF (2000)	38.185	38.19
1	7091	PRESSURE SW, ALARM (2000)	38.185	38.19
1	6043	PC0727P01 GASKET, MOLDED, TOP HSG (2000 CORE ONLY)	11.4555	11.46
All material remains the property of Site Specific Design until final payment.			Total	\$457.84

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.