

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Invoice

Date	Invoice #
9/20/2022	67116

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/20/2022			
Qty	Item Code	Description			Price Each	Amount
1 2.5	Service/Ins Labor-PB	Replace A263900 with new Twp pump DH808800 Date of service 9/20/22 Technician Pat Brady Arrived on site and found pump A263900 in alarm and not pumping out.took meter readings and ground to black red to black readings were incorrect.Pulled pump for further evaluation and found top control housing bolt holes are corroded through.Installed a new upper providence pump DH808800 and pump goes into and out of alarm and from on/off 33 seconds at 5.7 amps pump is running correctly Service Call & Inspection Fee < Labor rate for Pat			150.00 110.00	150.00 275.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$425.00
Sales Tax (0.0%)	\$0.00
Total	\$425.00
Payments/Credits	\$0.00
Total Due	\$425.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.