

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Invoice

Date	Invoice #
9/20/2022	67117

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	9/20/2022			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins 1 Labor-PB	Replace DH433605 with new Twp pump DH808804 Date of service 9/20/22 Technician Pat Brady Arrived on site and found pump DH433605 in alarm and not running.all meter readings were incorrect.Pulled pump for further evaluation and found corroded through bolt holes on control housing and motor was flooded.Installed new upper providence core DH808804 cycled pump few times pump goes into and out of alarm and from on/off 30 seconds at 5.8 amps pump is running correctly Service Call & Inspection Fee < Labor rate for Pat		150.00 110.00	150.00 110.00	

All material remains the property of Site Specific Design until final payment.

Subtotal	\$260.00
Sales Tax (0.0%)	\$0.00
Total	\$260.00
Payments/Credits	\$0.00
Total Due	\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.