

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001

# Invoice

Date	Invoice #
9/23/2022	67178

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	DR	9/23/2022			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace A122649 with new Twp pump dh808943  Date of service 9/23/22 Technician Dylan Rearick  Arrived on site, power to panel good, station not in alarm. Ran water, station went into alarm before turning on and did not pump out, pump also runs loudly, bearings worn out. Pulled A122649 from station and found bearings worn out and switches corroded and motor controls burnt, pump requires rebuild or replacement. Went to shed and installed dh808943 in station and tested successfully. Job complete.			150.00	150.00
2	Labor-DR	Service Call & Inspection Fee < Labor Rate for Dylan Rearick			110.00	220.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$370.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$370.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.