

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001

Invoice

Date	Invoice #
9/26/2022	67211

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	DR	9/26/2022			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Repair DH385750 Jairo Lora 7 Camby Chase rd Media Pa 19063				
1	Labor-DR	Date of service 9/26/22 Technician Dylan Rearick				
1	7290	Pump indicating overpressure. Reset breakers and trouble cleared. Inspected pump and found corroded switches, motor and motor controls fine and stator in good working order. Reinstalled pump and system pump through both switches. Job complete.				
1	7291	Service Call & Inspection Fee < Labor Rate for Dylan Rearick PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01 PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02			150.00 0.00 38.185	150.00 0.00 38.19
1					38.185	38.19

All material remains the property of Site Specific Design until final payment.

Subtotal	\$226.38
Sales Tax (0.0%)	\$0.00
Total	\$226.38
Payments/Credits	\$0.00
Total Due	\$226.38

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.