

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001

Invoice

Date	Invoice #
10/1/2022	67312

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	DR	10/1/2022			
Qty	Item Code	Description			Price Each	Amount
1	Emergency 1 Labor-DR	Repair DH385740 7 Camby Chase Road Media, PA 19063 Date of service 10/1/22 Technician Dylan Rearick Arrived on site, power to panel good, meter checks normal. Panel indicating pump running and in alarm but contactor not made and will not make or run pump. Pulled vacuum on pump and it ran. Plugged in spare and it also ran. Wired pump lines directly into breakers and township pump turned on and pump out station at 5.8 amps. No contactor on truck, will have to return during week to replace contactor and check to ensure panel board works, it is unburnt and voltage is good to leads. Emergency Weekend/After Hours Rate Emergency Labor Rate for Dylan Rearick		165.00 165.00	165.00 165.00	

All material remains the property of Site Specific Design until final payment.

Subtotal	\$330.00
Sales Tax (0.0%)	\$0.00
Total	\$330.00
Payments/Credits	\$0.00
Total Due	\$330.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.