

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001

Invoice

Date	Invoice #
10/13/2022	67507

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project			
	Net 30	PB	10/13/2022						
Qty	Item Code	Description			Price Each	Amount			
1	Service/Ins	Replace A237966 with new Twp core DH812625 781 Farnum Road Media, PA 19063							
3	Labor-PB	Date of service 10/13/22 Technician Pat Brady							
1	9512	Arrived on site and found pumpA237966 in alarm andstation completely flooded.performed meter readings and all readings were incorrect. Printed circuit board was burnt on the back. Pulled pump for further evaluation and found Control housing cracked and rotor was locked up.installed upper providence new coreDH812625 .and printed circuit board. Pump goes into and out of alarm and from on/off 33 seconds at 5.8 amps pump is running correctly							
		Service Call & Inspection Fee < Labor rate for Pat PA1093G18 SIMPLEX PBC BOARD W/DIN RAIL MOUNTS			150.00 110.00 138.0115	150.00 330.00 138.01			
All material remains the property of Site Specific Design until final payment.						Subtotal \$618.01			
						Sales Tax (0.0%) \$0.00			
						Total \$618.01			
						Payments/Credits \$0.00			
						Total Due \$618.01			