

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001

# Invoice

Date	Invoice #
10/14/2022	67534

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	10/14/2022			
Qty	Item Code	Description			Price Each	Amount
1 2.5	Service/Ins Labor-PB	Replace DH447529 with new Twp pump DH812617 235 East Rose Tree Road Media, PA 19063  Date of service 10/14/22 Technician Pat Brady  Arrived on site and found pump DH447529 in high level and over pressure alarm. Meter readings on brown to red and black were incorrect went to pulled pump for further evaluation. Station was completely flooded. Pump out of station and amps were 19 and 20 amps. and motor megs bad put in upper providence new core DH812617 pump goes into and out of alarm and from on/off 30 seconds at 6.1 amps pump is running correctly  Service Call & Inspection Fee < Labor rate for Pat		150.00 110.00	150.00 275.00	

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$425.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$425.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$425.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.