

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001

Invoice

Date	Invoice #
10/19/2022	67588

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	DR	10/19/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH385740 Jairo Lora (Upper Prov) 7 Camby Chase Road Media, PA 19063 Date of service 10/19/22 Technician Dylan Rearick No contactor on truck from previous visit dated 10/1/22. Returned to replace contactor and check to ensure panel board works, it is unburnt and voltage is good to leads. Replaced 7104 contactor and required panel. Ran water and tested station successfully. Job complete.		
1	Labor-DR	Labor Rate for Dylan Rearick	0.00	0.00
1	7104	PA 1476P01 Contactor Control Clip Motor 220v/240v (Alarm Panels & 2000 Series flat control bracket)	37.094	37.09

All material remains the property of Site Specific Design until final payment.

Subtotal \$37.09

Sales Tax (0.0%) \$0.00

Total \$37.09

Payments/Credits \$0.00

Total Due \$37.09

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.