

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001

# Invoice

Date	Invoice #
10/24/2022	67633

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	DR	10/24/2022			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace A122743 with new Twp core dh815852 Dan Gura (Upper Prov) 650 South Ridley Creek Road Media, PA 19063				
2	Labor-DR	Date of service 10/24/22 Technician Dylan Rearick				
1	1224	Arrived on site, power to panel normal, pump not in alarm. System pulled 9 amps when called and bearings incredibly loud. Pulled pump, bearings worn out and barely move, and stator and cutter wheel worn out. Pump requires replacement. Pulled last pump from township shed and installed and tested successfully. Job complete.				
		Service Call & Inspection Fee < Labor Rate for Dylan Rearick PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core			150.00 68.1875 0.00	150.00 136.38 0.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

<b>Subtotal</b>	\$286.38
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$286.38
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$286.38