

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
11/21/2023	72859

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/21/2023			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins 3 Labor-PB	Replace A151789 with new twp pump DH870126 Kenny Jecaell (Upper Prov) 795 North Ridley Creek Road Media, PA 19063 Date of service 11/21/23 Technician Pat Brady Arrived on site and found pump A151789 in alarm and not pumping out all readings were incorrect. Pulled pump for further evaluation and found station full of wipes and female products pump had corroded motor housing and a cracked top housing. due to age of pump installing new upper providence core DH870126 pump goes into and out of alarm and from on/off 30 at 6.2 amps Service Call & Inspection Fee < Labor rate for Pat				
					150.00 120.00	150.00 360.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$510.00
Sales Tax (0.0%)	\$0.00
Total	\$510.00
Payments/Credits	\$0.00
Total Due	\$510.00

**OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER**


12/04/2023