

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
11/22/2023	72883

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/22/2023			
Qty	Item Code	Description			Price Each	Amount
		Repair DH486407 Chris Sowa (Upper Prov) 70 Kingston Road Media, PA 19063 Date of service 11/22/23 Technician Pat Brady Arrived on site and found pump DH486407 in high level alarm and not running. Performed meter readings and brown to red was incorrect. Pulled pump for further evaluation and found corroded switches. control Bracket motor and stator checked out good. Station had chunks of grease I cleaned out station best I could in new switches put pump back into station. pump pumped down and off at 6.3 amps pump is running correctly			<b>OK TO PAY</b> <b>KEVIN MATSON, PE,</b> <b>OPERATIONS MANAGER</b>  <b>12/04/2023</b>	
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
2	Labor-PB	Labor rate for Pat			120.00	240.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings			43.88002	43.88
1	7291	NB0083G01 PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02			43.88002	43.88

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$477.76
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$477.76
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$477.76