

Site Specific Design, Inc.


1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
11/29/2023	72953

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/29/2023			
Qty	Item Code	Description			Price Each	Amount
		DH823940 Maria & Jeff Anderson (Upper Prov) 9 West Bishop Hollow Road Media, PA 19063 Date of service 11/29/23 Technician Pat Brady Red light & alarm on grinder pump. Arrived on site and found pump DH823940 not in alarm and all meter readings were correct. Ran water to cycle the pump and pump went into and out of alarm and found on/off 32 seconds at 5.8 amps. Pulled pump for further evaluation and found sensing Column on the on/off side was clogged with grease and wipes also station had a lot of wipes and grease. Checked switches control Bracket and Stator all checked out good and megged house side cable also checked out good. Cleaned out station best I could and reinstalled pump back into station cycled the pump pumped down and shut off at 5.9 amps pump is running correctly.			OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  12/04/2023	
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
2	Labor-PB	Labor rate for Pat			120.00	240.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$390.00
Sales Tax (0.0%)	\$0.00
Total	\$390.00
Payments/Credits	\$0.00
Total Due	\$390.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.