

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
11/30/2023	72964

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/30/2023			
Qty	Item Code	Description			Price Each	Amount
		Replace A137698 with new twp pump DH870166 Faith Balsama- (Upper Prov) 582 Kirk Lane Media, PA 19063 Date of service 11/30/29 Technician Pat Brady Arrived on site and found station not in alarm but pump A137698 bearings are very noisy Homeowner ran some water and the water started to come up on other side of tank. Pulled pump A137698 motor housing corroded beyond repair and due to age of pump in new upper providence core DH870166 pump pumped out of alarm and off at 5.6 amps pump is running correctly. Kevin from upper providence township is being contacted about broken discharge.			OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER	
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
3	Labor-PB	Labor rate for Pat			120.00	360.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$510.00
Sales Tax (0.0%)	\$0.00
Total	\$510.00
Payments/Credits	\$0.00
Total Due	\$510.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.