

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/12/2024	74226

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	3/4/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433715 with new twp pump DH880477 Eric Chung (Upper Prov) 40 Kingston Rd Media, Pennsylvania 19063-1851				
		Date of service 3/4/24 Technician Pat Brady				
		Arrived on site and found pump DH433715 in high level alarm and not pumping out Took meter readings there were short to all pump leads pulled pump for further evaluation and found control housing and motor housing corroded beyond repair. Installed new upper Providence core DH880477 pump pumped down and shut off at 5.9 amps pump is running correctly. Will need to return at some point to install 6" riser				
		3/12/24 pat Return to site to install a 6" riser riser had been installed				
1.5	Labor-PB	Labor rate for Pat			127.50	191.25
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00
1	ND0082G01	6 inch Cover Shroud Riser Kit, E/One Extender			362.049	362.05

All material remains the property of Site Specific Design until final payment.

Subtotal	\$853.30
Sales Tax (0.0%)	\$0.00
Total	\$853.30
Payments/Credits	\$0.00
Total Due	\$853.30

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.