

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/4/2024	74228

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	3/8/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH420601 with new twp pump DH880478 Stephen Slawek (Upper Prov) 441 Foxchase Dr Media, Pennsylvania 19063-1937				
		Date of service 3/4/24 Technician Pat Brady				
		Arrived on site and found pumpDH420601 in high level alarm and station buried. Took meter readings and brown to black and red were incorrect. Dugout station pulled pump for further evaluation and found heavily corroded and due to age of pump installed new upper Providence core DH880478 pump pumped down and shut off at 6.1 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

OK TO PAY
KEVIN MATSON, PE,
OPERATIONS MANAGER


4/8/2024