

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/9/2024	74348

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SM	3/9/2024			
Qty	Item Code	Description			Price Each	Amount
OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER		Repair DH410201 Don Saleski (Upper Prov) 1800 N Ridley Creek Rd Media, Pennsylvania 19063-4529				
 4/8/2024		Date of service 3/9/24 Technician Shawn McKee Red light on buzzing. Inspected pump dh410201 to find corroded switches burnt controls an worn stator. Tested motor and tested good replaced switches controls a stator. Reinstalled pump. Left at 330. Home at 530.				
1.5	Labor-SM	Emergency Labor-Shawn M			225.00	337.50
1	Emergency	Emergency Weekend/After Hours Rate			200.00	200.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings			68.374	68.37
1	7291	NB0083G01 PRESSURE SWITCH, ALARM EXTREME w/ O-rings			68.374	68.37
1	1265	NB0083G02 CONTROL BRACKET ASM, 240V/60HZ ND0045G01			253.3561	253.36
1	8203	STATOR/LINER ASSY EXTREME NC0039G01			92.6126	92.61

All material remains the property of Site Specific Design until final payment.

Subtotal	\$1,020.21
Sales Tax (0.0%)	\$0.00
Total	\$1,020.21
Payments/Credits	\$0.00
Total Due	\$1,020.21

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.