

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/13/2024	74374

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	3/13/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH434110 with new twp pump DH879581 Joe Garvey (Upper Prov) 60 Daria Rose Ct Media, Pennsylvania 19063-1187				
		Date of service 3/13/24 Technician John Simons				
		Arrived on site to find no alarm. Customer stated that the panel would chirp intermittently. Performed meter test and all readings were correct. Had the customer run some water and as soon as the pump turned on the panel started the chirp but it wasn't a high-level Alarm. Removed the lid to Station and found that DH434110 was manufactured 03/2012. Due to the age of the pump, and the fact that it had been worked on prior, retrieved a new Township core from the shed and installed into Station. Also extended the L1 and L2 supply cable wires in the panel because they were pulled tight. Manually tested DH879581 and it operates at 6.0 amps. Job complete				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-JS	Labor rate for John Simons			130.00	130.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants			22.9925	22.99

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$322.99
	Sales Tax (0.0%)	\$0.00
	Total	\$322.99
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$322.99