

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/13/2024	74375

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	3/13/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH823952 Christina Salemo (Upper Prov) 141 Foxcatcher Lane Media, PA 19063				
		Date of service 3/13/24 Technician John Simons				
		Arrived on site to find no alarm. Performed meter test and all readings are correct. Asked the customer what was happening and they said that the contactor in the panel would sometimes buzz and hum. Replaced the contactor in the panel. Also tightened the Hubble nut for supply cable entry. Manually tested pump DH823952 and it operates at 5.8 amps. Job complete				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
1	Labor-JS	Labor rate for John Simons			130.00	130.00
1	7104	PA 1476P01 Contactor Control Clip Motor 220v/240v (Alarm Panels & 2000 Series flat control bracket)			66.0025	66.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$366.00
	Sales Tax (0.0%)	\$0.00
	Total	\$366.00
	Payments/Credits	\$0.00
	Total Due	\$366.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.