

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
3/20/2024	74493

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JohnS	3/20/2024			
Qty	Item Code	Description			Price Each	Amount
		Evaluate DH865049 Nicole & Herb Phillips (Upper Prov) 10 Ruskin Ln Media, Pennsylvania 19063-2234				
		Date of service 3/20/24 Technician John Simons				
		Arrived on site to find panel indicating a high-level and normal light but the pump is not running. Performed a meter check and had 245 V supplied to the pump. Also found the both switches were made. Peco is at the end of the road doing work when the customer said they had some type of power issue prior to me arriving. Turned the breakers off and on again and pump DH865049 turned on and ran at 5.8 amps. Once the alarm cleared the pump finished out its cycle and shut off. had the customer turn on two sinks in a tub and cycled the pump for about 10 minutes. Suspect there was a power issue which caused the MCB to lock out. Could not find anything wrong with the pump. Job complete.				
1	Service/Ins 1 Labor-JS	Service Call & Inspection Fee < Labor rate for John Simons			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.