

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
3/27/2024	74558

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	3/26/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH808790 Sam Grace (Upper Prov) 4 Camby Chase Road Media, PA 19063				
		Date of service 3/27/24 Technician Pat Brady				
		Arrived on site and found pump DH808790 in high level alarm and not running. Took meter reading all readings were incorrect. Went to pull pump for further evaluation and found station completely flooded. Disconnected EQD was not flooded. pulled pump and control bracket switches and motor all checked out good. Removed printed circuit board and found the back of it was burnt due to a slug. I seal off the conduit, changed out printer circuit board pump pumped down and shut off at 6.0 A pump is running correctly.				
1	Service/Ins	Service Call & Inspection Fee <			170.00	170.00
2	Labor-PB	Labor rate for Pat			127.50	255.00
1	9543	NB0072G21 Sentry Protect Panel PCB Board Alarm Replacement 240V			363.2101	363.21

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$788.21
	Sales Tax (0.0%)	\$0.00
	Total	\$788.21
	Payments/Credits	\$0.00
	Total Due	\$788.21