



Water & Wastewater Infrastructure Services

Fax: 610-444-8132

439 McFarlan Road  
Kennett Square, PA 19348  
Phone: 610-444-3551

June 2024

Attention: Ms. Kelly Verna  
935 N. Providence Road  
Media, PA. 19063

RE: Sanitary Sewer Operations Maintenance Supervisors Report- June- 2024

**1. Operational Status of the facilities & General Pump Station Status**

KBX performed the following general pump station repairs and observations:

**June - 2024-general pump station repairs:**

**General Collections:**

- 6/28/24- Quarterly Cleaning at Farnum and Crum Creek.

**Bordtondale:**

- Routine Maintenance

**Braves Trail:**

- 6/24/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.

**Letitia Lane Pump Station:**

- Routine Maintenance

**Media Station:**

- Routine Maintenance

### Rose Tree Lower

- 6/24/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.
- 6/27/24- Troubleshoot dialer. Programed numbers that were previously incorrect. Tested High Water alarms.

### Rose Tree Park

- 6/23/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.
- 6/24/24- Responded to power failure alarm. Power restored upon arrival. Both thermals had tripped. Reset. The Surge protector has a light out and will need to be replaced. Observed proper operation before departure,

### Rose Tree Upper

- 6/24/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.
- 6/27/24- Troubleshoot dialer. Programed numbers that were previously incorrect. Tested High Water alarms.

### Toft Woods:

- Routine Maintenance

### Valley View:

- Routine Maintenance

### Winter Street:

- 6/4/24- Confirmed that storm lines run as plan indicates on Winter Street.
- 6/23/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.
- 6/24/24- Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.

Recommendations for Repairs\*\*

\*\*\*Please inform us which repairs are the responsibility of the contractor who did the station build outs and upgrades and which you would like us to attend to/fix.

Please let us know if you have any questions or concerns.

KBX Golden, LLC  
439 McFarlan Road  
Kennett Square, Pa.