

**UPTSA January 2024 Pump Station Invoices**

**Upper Prov./Operations & Maintenance**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/1/2024	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6560002485
							<b>Pump Station Total</b>	<b>\$7,240.33</b>	

**Upper Prov./Bortondale**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/14/2024	Upper Providence/Bortondale	26733442	1930598	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Installed new new left hand check valve and gaskets on side #2	\$315.63	6560004194
6/14/2024	Upper Providence/Bortondale	26733442	1930598		Project-Materials	\$819.59	Check Valve and Gaskets	\$819.59	6560004194
6/14/2024	Upper Providence/Bortondale	26733442	1930598	3	Project-C-Hours-Mechanic	\$97.54	Installed new new left hand check valve and gaskets on side #2	\$292.62	6560004195
							<b>Pump Station Total</b>	<b>\$1,427.84</b>	

**Upper Prov/Braves Trail**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/24/2024	Upper Providence/Braves Trail	2673442	1930600	4	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$631.28	6560004284
							<b>Pump Station Total</b>	<b>\$631.28</b>	

**Upper Prov/Rosetree Estates Upper**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/24/2024	Upper Providence/Rose Tree Estates Upper	2673442	1930605	1	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$157.82	6560004286
6/27/2024	Upper Providence/Rose Tree Estates Upper	2673442	1930605	1	Project-C-Hours-Foreman-Mechanic	\$105.21	Troubleshoot dialer. Programed numbers that were previously incorrect. Tested High Water alarms.	\$105.21	6560004332
							<b>Pump Station Total</b>	<b>\$263.03</b>	

**Upper Prov./Winters Street**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/4/2024	Upper Providence/Winter Street	2673442	1930611	2	Project-C-Hours-Foreman-Mechanic	\$105.21	Confirmed that storm lines run as plan indicates on Winter Street.	\$210.42	6560004100
6/23/2024	Upper Providence/Winter Street	2673442	1930611	1	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$157.82	6560004272
6/24/2024	Upper Providence/Winter Street	2673442	1930611	1	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$157.82	6560004288
							<b>Pump Station Total</b>	<b>\$526.06</b>	

**Upper Prov/Rosetree Estates Lower**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/24/2024	Upper Providence/Rose Tree Estates Lower	2673442	1930603	1	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$157.82	6560004285

6/27/2024	Upper Providence/Rose Tree Estates Lower	2673442	1930603	1	Project-C-Hours-Foreman-Mechanic	\$105.21	Troubleshoot dialer. Programed numbers that were previously incorrect. Tested High Water alarms.	\$105.21	6560004331
							<b>Pump Station Total</b>	<b>\$263.03</b>	

**Upper Prov./Rose Tree Park**

Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
6/24/2024	Upper Providence/Rose Tree Park	2673442	1930608	1	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Both thermals had tripped. Reset. Surge protector has a light out and will need to be replaced. Observed proper operation before departure,	\$157.82	6560004287
6/23/2024	Upper Providence/Rose Tree Park	2673442	1930608	4	Repair-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to power failure alarm. Power restored upon arrival. Observed proper operation before departure.	\$631.28	6560004271
							<b>Pump Station Total</b>	<b>\$789.10</b>	