

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
10/17/2024	77681

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/17/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH429495 with new twp pump DH912929  Tom Connelly (Upper Prov) 2273 E Deerfield Dr Media, Pennsylvania 19063-1833  Date of service 10/17/24 Technician Sebastian Gonzalez  Arrived on site to find panel not in alarm. Performed meter readings and all readings were bad. I pulled pump DH429495 and noticed that pump was from 01/2012. I went to upper Prov shed to grab customer new core DH00912929 once I put new core into station. I ran pump to alarm and performed my last meter checks and everything was good.			<b>OK TO PAY</b> <b>KEVIN MATSON, PE,</b> <b>OPERATIONS MANAGER</b>  <b>11-11-2024</b>	
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-SGon	Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$300.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$300.00