

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

Date	Invoice #
10/6/2024	77495

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	10/6/2024			

Qty	Item Code	Description	Price Each	Amount
		Repalce DH420929 with new twp pump DH914928 Elaine Gallo (Upper Prov) 545 South Avenue Media, PA 19063 Date of service 10/6/24 Technician Pat Brady Arrived on site and found pump DH420939 in alarm not running and station flooded took meter readings all were incorrect also buzzer button is corroded off due to age of pump installed new upper Providence core DH00914928 pump pumped down and shut off at 5.8 amps pump is running correctly		
1	Emergency	Emergency Weekend/After Hours Rate	200.00	200.00
1	Labor-PB	Emergency Labor rate for Pat	225.00	225.00



All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$425.00
Sales Tax (0.0%)	\$0.00
Total	\$425.00
Payments/Credits	\$0.00
Total Due	\$425.00