

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
10/21/2024	77590

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/10/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH430839 with new twp pump DH914947 Carlo Russo 160 Gordon Dr Media, Pennsylvania 19063-1942 Date of service 10/11/24 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm but the alarm breaker to panel was turned off. I performed meter readings and all readings were good on pump excepts amps on pump amps were running on 4.2. I lifted the lid to station to see station wasn't flooded. I pulled pump #DH430839 I also noticed that pump was from 02/2012 so I went to upper Prov shed. To grab customer new core #DH00914947 once I put core into station I ran pump to alarm. And performed my final meter readings and everything checked out good Job completed				
1	Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			297.50	297.50
					130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$427.50
Sales Tax (0.0%)	\$0.00
Total	\$427.50
Payments/Credits	\$0.00
Total Due	\$427.50

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.