

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
10/21/2024	77707

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/21/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins Labor-SGon	Replace DH401765 with new twp pump DH914941 95 W Rose Tree Date of service 10/21/24 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm. Performed meter readings and all readings were good except switches to pump and amps on pump were running low. I pulled pump DH401765 and I saw that pump was from 08/2011 I went to upper Prov shed to grab customer new core #DH00914941. Once I put new core into station I ran pump to alarm and performed my last meter readings and everything checked out good.			<div style="border: 2px solid red; padding: 5px; text-align: center;"> OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  11-11-2024 </div>	

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00