

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
10/29/2024	77857

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	10/29/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH425010 with new twp pump DH914938 Pat Jefferies (Upper Prov) 1755 Colt Rd Media, Pennsylvania 19063-1980 Date of service 10/29/24 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm but the alarm breaker to panel was turned off. Performed meter readings and all readings were good except switches and amps were really low. I lifted lid to station to find station flooded. I pulled pump DH425010 and saw that pump was from 12/2011. I went to upper Prov shed to grab customer new core DH00914938. Once I put new pump into station I ran pump to alarm and performed my last meter readings and everything checked out ok. Job completed.				
1	Service/Ins Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00