

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
10/30/2024	77862

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	10/31/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH486377 with new twp pump DH914949 Robert Zeiger (Upper Prov) 102 Cove Lane Media, PA 19063 Date of service 10/30/24 Technician Pat Brady Arrived on site and found pump DH486377 not in alarm and wouldn't run.all meter readings were incorrect.pulled pump for further evaluation found heavily corroded control housing and station had lots of grease cleaned out station best I could.due to the age of the pump installed new upper Providence core DH00914949 pump pumps down and shuts off at 6.5 amps pump is running correctly				
1	Service/Ins Labor-PB	Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00