

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
10/30/2024	77869

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	10/31/2024			
Qty	Item Code	Description			Price Each	Amount
		Replace DH433527 with new twp pump DH914951 Jim Barber (Upper Prov) 121 Paxon Hollow Rd Media, Pennsylvania 19063-1113 Date of service 10/30/24 Technician Pat Brady Arrived on site and found the breakers off to pump DH433527 turned breakers back on pump went in high level alarm and run dry Performed meter readings and all readings were incorrect.Due to age off pump installed new upper Providence core DH00914951 pump pumps down and shuts off at 5.7 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.