

UPTSA 2024 Pump Station Invoices

Upper Prov./Operations & Maintenance

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|---|---------|----------|-------|--|----------------|---------------------------|-------------------|------------|
| 12/1/2024 | Upper Providence Township Sewer Authority | 2673442 | 1930867 | 1 | IS-C-WWTP-Lift & Pump Station Operations | \$7,240.33 | Monthly O&M | \$7,240.33 | 6560004695 |
| | | | | | | | Pump Station Total | \$7,240.33 | |

Upper Prov./Bortondale

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|-----------------------------|---------|----------|-------|------------------------------------|----------------|---|-----------------|------------|
| 12/3/2024 | Upper Providence/Bortondale | 2673442 | 1930598 | 1 | Repair-C-Hours-Foreman-Mechanic | \$105.21 | Responded to a high water and back up float system active alarms. Upon arrival, contractors were on site doing demolition work on old station. | \$105.21 | 6560006042 |
| 12/3/2024 | Upper Providence/Bortondale | 2673442 | 1930598 | 1 | Repair-C-Hours-Foreman-Mechanic-OT | \$157.82 | Responded to high water/back up float alarm. Contractor's cause of alarms. | \$157.82 | 6560006044 |
| 12/13/2024 | Upper Providence/Bortondale | 2673442 | 1930598 | 4 | Project-C-Hours-Foreman-Mechanic | \$105.21 | Responded to a pump #2 high water alarm. Found an inoperable soft start. Contractor installed new Soft Start. Observed proper operation before departure. | \$420.84 | 6560006112 |
| 12/19/2024 | Upper Providence/Bortondale | 2673442 | 1930598 | 1 | Project-C-Hours-Foreman-Mechanic | \$105.21 | Met with contractor for Soft Start installation. | \$105.21 | 6560006164 |
| | | | | | | | Pump Station Total | \$789.08 | |

Upper Prov/Valley View

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|------------------------------|---------|----------|-------|-------------------------------------|----------------|--|-----------------|------------|
| 12/15/2024 | Upper Providence/Valley View | 2673442 | 1930609 | 4 | Project-C-Hours-Foreman-Mechanic-OT | \$157.82 | Responded to a lag alarm. Cleaned solenoid #2. Observed proper operation before departure. | \$631.28 | 6560006113 |
| | | | | | | | Pump Station Total | \$631.28 | |

Upper Prov./Winters Street

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|--------------------------------|---------|----------|-------|-------------------------------------|----------------|---|-------------------|------------|
| 12/15/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 4 | Project-C-Hours-Foreman-Mechanic-OT | \$157.82 | Responded to high water alarm. Upon arrival found pump #1 had tripped at thermal. Call in vacuum truck. Cleaned contacts and reset thermal. Observed proper operation before departure. | \$631.28 | 6560006114 |
| 12/15/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 4 | Project-C-Hours-Pump Truck-OT | \$291.68 | Emergency call out for highwater alarm. | \$1,166.72 | 6560006115 |
| 12/3/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 4 | Repair-C-Hours-Foreman-Mechanic-OT | \$157.82 | Responded to lag alarms. Upon arrival pump #2 was shorted to ground. Put pump #1 in lead. Observed proper operation beforew departure. | \$631.28 | 6560006043 |
| 12/4/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 1 | Project-C-Hours-Foreman-Mechanic | \$105.21 | On site to determine brand of pump to be ordered. | \$105.21 | 6560006049 |
| 12/19/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 3 | Project-C-Hours-Foreman-Mechanic | \$105.21 | Pulled pump #2 to retrieve tag information to order pump replacement. | \$315.63 | 6560006165 |
| 12/19/2024 | Upper Providence/Winter Street | 2673442 | 1930611 | 3 | Project-C-Hours-Mechanic | \$97.54 | Pulled pump #2 to retrieve tag information to order pump replacement. | \$292.62 | 6560006166 |
| | | | | | | | Pump Station Total | \$3,142.74 | |

Upper Prov/Rosetree Estates Lower

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|--|---------|----------|-------|----------------------------------|----------------|--|-----------------|------------|
| 12/31/2024 | Upper Providence/Rose Tree Estates Lower | 2673442 | 1930603 | 1 | Project-C-Hours-Foreman-Mechanic | \$105.21 | Troubleshoot pump #1. Found a broken auxiliary, although still working will need to be replaced. | \$105.21 | 6560006273 |
| | | | | | | | Pump Station Total | \$105.21 | |

Upper Prov./Rose Tree Park

| Service Date: | Location | Cust# | Jobsite# | Hours | Line item | Price per hour | Tech notes: | Total per WO | WO# |
|---------------|---------------------------------|---------|----------|-------|----------------------------------|----------------|----------------------------|-----------------|------------|
| 12/5/2024 | Upper Providence/Rose Tree Park | 2673442 | 1930608 | 2 | Project-C-Hours-Foreman-Mechanic | \$105.21 | Filled generator with fuel | \$210.42 | 6560006070 |
| 12/5/2024 | Upper Providence/Rose Tree Park | 2673442 | 1930608 | 1 | Project-Materials | \$273.60 | 60 Gallons of Fuel | \$273.60 | 6560006070 |
| | | | | | | | Pump Station Total | \$484.02 | |