

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
1/31/2025	79008

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/31/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH305516 with new twp pump DH923356 Jeff Rubesin (Upper Prov) 11 Ruskin Ln Media, Pennsylvania 19063-2202 Date of service 1/31/25 Technician Pat Brady Arrived on site and found pump DH305516 in alarm and not running. Took meter readings and brown to red and black were incorrect. Pulled pump for further evaluation and found pump was heavily corroded and due to the age of the pump installed new upper Providence core DH00923356 pump has been installed and cycled pump pumped out of alarm and off at 6.2 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
1	Labor-PB	Labor rate for Pat			130.00	130.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
	Payments/Credits	\$0.00
	Total Due	\$300.00

