

## *Site Specific Design, Inc.*

1704 Rockwell Road  
Abington, PA 19001



## Invoice

Date	Invoice #
1/30/2025	77801

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	10/25/2024			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins Labor-PB	Evaluate DH431823  Robert Stott (Upper Prov) 32 Steeplechase Dr Media, Pennsylvania 19063-1953  Technician Pat Brady  Arrived on site at Kevin Matson request to check out the pump DH431823 meter readings all readings are correct had customer run some water and it wasn't making it to the station.Ran a hose to the pump pump pumped down and shut off at 5.7 amps pump is running correctly at this time homeowner is having a plumber come out to snake the line  Service Call & Inspection Fee Labor rate for Pat			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$300.00
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$300.00
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$300.00