

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
1/6/2025	78579

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/6/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH429225 with new twp pump DH921774 460 Paxon Hollow rd Date of service 12/31/24 Technician Pat Brady & Sebastian Gonzalez Arrived on site to find panel not in alarm. But panel was wired up completely wrong and contactor in panel was missing and all wires were disconnected. Customer also had main breakers turned off to the pump. I rewired all the wires to panel to find out that PCB in panel was bad I replaced PCB with a new one and saw that panel was reading high level alarm and brownout light came on. I informed Scott about the situation and I also let him know that pump is from 09/2012 and I was putting in SSS #DH386046 and took DH429225. I ran spare into alarm and had customer run water so I can run pump into its normal cycle. Job completed will need to return to install upper Prov pump. 12/31/24 pat Arrived on site to pull site spare and install new upper Providence core DH00921774 also check out panel. Everything in the panel is correct. Installed new				

All material remains the property of Site Specific Design until final payment.

Subtotal

Sales Tax (0.0%)

Total

Payments/Credits

Total Due

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
1/6/2025	78579

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/6/2025			
Qty	Item Code	Description			Price Each	Amount
1	Pump Truck	pump pumped down and shut off at 6.1 amps pump is running correctly			441.80	441.80
1	Labor-SGon	Pump truck called out to evacuate station.			130.00	130.00
1	Labor-PB	Labor rate for Sebastian			130.00	130.00
1	Service/Ins	Labor rate for Pat			170.00	170.00
Service Call & Inspection Fee						

All material remains the property of Site Specific Design until final payment.

Subtotal	\$871.80
Sales Tax (0.0%)	\$0.00
Total	\$871.80
Payments/Credits	\$0.00
Total Due	\$871.80

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.