

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
1/14/2025	78779

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	1/14/2025			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Replace DH433862 with new twp pump DH923330 Sean Wright (Upper Prov) 182 Dam View Rd Media, Pennsylvania 19063-1832 Date of service 1/14/25 Technician Sebastian Gonzalez Arrived on site to find panel in alarm. Performed meter readings and all readings to pump were good except amps pump wasn't running when I held down the run button in panel. I pulled pump DH433862 and I saw that pump was from 06/2012 I went to upper Prov shed to grab customer new core DH00923330. I put new core into station and ran pump to alarm. Performed my last meter readings and all readings were correct. New core amps are 5.6/5.8 amps.			170.00	170.00
1	Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			130.00	130.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$300.00
	Sales Tax (0.0%)	\$0.00
	Total	\$300.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Payments/Credits	\$0.00
	Total Due	\$300.00