

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

| Date      | Invoice # |
|-----------|-----------|
| 1/18/2025 | 78848     |

| Bill To   | Ship To   |
|---|---|
| Upper Providence Township<br>Attn: Kevin Matson, Sewer Authority<br>935 N. Providence Road<br>Media, PA 19063 | Upper Providence Township<br>935 N Providence Road<br>610-566-5376<br>Media, PA 19063 |

| Cust. PO # | Terms                         | Rep  | Ship Date | Ship Via         |                  | Project |
|------------|-------------------------------|--|-----------|------------------|------------------|---------|
|            | Net 30                        | Jon M  | 1/18/2025 |                  |                  |         |
| Qty        | Item Code                     | Description  |           |                  | Price Each       | Amount  |
| 1          | Emergency<br>1<br>Labor-Jon M | Replace pump with new twp pump DH819814<br><br>Jeff McCampbell (Upper Prov)<br>6 Azalea Lane<br>Media, PA 19063<br><br>Arrived on site, station was not in active alarm. Inspect panel, panel condition OK. Customer directed me to where the water was coming from. Manually ran the pump and as the pump ran, wastewater was bubbling up out of the ground. Notified customer it is a broken discharge outside the tank. Notified Kevin Matson w/ UPPER PROV TWP.<br><br>New core installed approx two years ago. DH819814.<br><br>Emergency Weekend/After Hours Rate<br>Emergency Labor-Jon M |           | 200.00<br>225.00 | 200.00<br>225.00 |         |

All material remains the property of Site Specific Design until final payment.

|                         |          |
|-------------------------|----------|
| <b>Subtotal</b>         | \$425.00 |
| <b>Sales Tax (0.0%)</b> | \$0.00   |
| <b>Total</b>            | \$425.00 |
| <b>Payments/Credits</b> | \$0.00   |
| <b>Total Due</b>        | \$425.00 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.