

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

215-887-3730

Date	Invoice #
1/21/2025	78870

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	1/21/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH354937 & DH388672 with new twp pumps DH923329 & DH923363 Providence Animal Shelter (Upper Prov) 555 Sandy Bank Rd Media, Pennsylvania 19063-1334 Date of service 1/21/25 Technician Pat Brady Arrived on site and found neither pump in alarm also wouldn't run when manual run was pushed on both pumps. Meter readings to pump 1 DH354937 red to black was fluctuating red to white was incorrect pump 2 DH388672 red to white incorrect red to black same thing you fluctuating Shoveled out the station pulled both pumps and due to age and corrosion installed two new upper Providence cores DH00923329 DH00923363 both pumps pumped down and shut off at 6.6 - 7.3 amps Pumps are running correctly.				
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
3	Labor-PB	Labor rate for Pat			130.00	390.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$560.00
Sales Tax (0.0%)	\$0.00
Total	\$560.00
Payments/Credits	\$0.00
Total Due	\$560.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.