

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001




Invoice

215-887-3730

Date	Invoice #
1/23/2025	78892

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JonS	1/23/2025			
Qty	Item Code	Description			Price Each	Amount
		Jeff & Anne Wack (Upper Prov) 180 Clearwater Dr Media, Pennsylvania 19063-1848 Date of service 1/23/24 Technician Jon Smith DH732897 02/21 Arrived and found pump running off of alarm circuit. Pulled pump and switches looked good. Resistor for on/off looked loose. Replaced both resistors. Tested pump. It ran the first time. Went into alarm second time. Pulled pump and replaced on/off switch. Tested pump again. It ran the first time and went into alarm the second time. Pulled pump and ohm checked switch. It worked every time. Suspect bad controller. Replaced controller and system started working properly. Pump runs at 3.0-3.4a.			OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  2/11/2025	
1	Service/Ins	Service Call & Inspection Fee			170.00	170.00
2	Labor-JJ	Labor rate for Jonathan Smith			130.00	260.00
1	Misc.	Sigma controller for 3 phase control panel			425.00	425.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$855.00
Sales Tax (0.0%)	\$0.00
Total	\$855.00
Payments/Credits	\$0.00
Total Due	\$855.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.