

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001



# Invoice

215-887-3730

Date	Invoice #
1/23/2025	78903

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	JonS	1/23/2025			
Qty	Item Code	Description			Price Each	Amount
1	Service/Ins	Unitarian Universalist Church of Delaware County (Upper Prov) 145 W Rose Tree Rd Media, Pennsylvania 19063-2008  Date of service 1/23/25 Technician Jon Smith  Eone Duplex w/pp panel No power to station. Station is overflowing. Found that breaker in panel was off. Turned breaker on and system went into alarm. Labeled breaker. Both pumps ran. With both pumps running amps were at 6.9-7.0a. Voltage was 242. Pumps ran and pumped out of alarm. With 1 pump running amps are 5.9. Drained dry access way. Both pumps shut off. Checked both bladders, ok. System is now working properly.			OK TO PAY <b>KEVIN MATSON, PE, OPERATIONS MANAGER</b>   2/11/2025	170.00
		Service Call & Inspection Fee				170.00

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	<b>Subtotal</b>	\$170.00
	<b>Sales Tax (0.0%)</b>	\$0.00
	<b>Total</b>	\$170.00
Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	<b>Payments/Credits</b>	\$0.00
	<b>Total Due</b>	\$170.00