

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



Invoice

Date	Invoice #
1/24/2025	78922

215-887-3730

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	SGon	1/24/2025			
Qty	Item Code	Description			Price Each	Amount
		Replace DH496332 with new twp pump DH923303 Vincent Ross (Upper Prov) 128 Mansion Dr Media, Pennsylvania 19063-1043 Date of service 1/24/25 Technician Sebastian Gonzalez Arrived on site to find panel not in alarm. Customer had shut off the alarm breaker to panel once I flipped the breaker on the panel went straight to alarm. Performed meter readings and all readings to pump were good except switches and I wasn't getting any amp draws to pump. I pulled pump DH496332 and saw that pump was from 9/2014 I went to upper Prov shed to grab customer new core DH00923303. I put new core into station and ran pump to alarm. I had customer run water so I can run pump to its normal cycle. Amps on new core is 5.8 amps.			OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  2/11/2025	
1	Service/Ins Labor-SGon	Service Call & Inspection Fee Labor rate for Sebastian			170.00 130.00	170.00 130.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$300.00
Sales Tax (0.0%)	\$0.00
Total	\$300.00
Payments/Credits	\$0.00
Total Due	\$300.00