

UPTSA 2024 Pump Station Invoices									
Upper Prov./Operations & Maintenance									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/1/2025	Upper Providence Township Sewer Authority	2673442	1930867	1	IS-C-WWTP-Lift & Pump Station Operations	\$7,240.33	Monthly O&M	\$7,240.33	6560005368
							Pump Station Total	\$7,240.33	
Upper Prov./Bortondale									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/16/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Respond to power failure during heavy wind event. Called in Vacuum truck to help maintain station. Called power failure into Peco.	\$631.28	6588182128
2/16/2025	Upper Providence/Bortondale	2673442	1930598	4	Project-C-Hours-Pump Truck-OT	\$291.68		\$1,166.72	6560006679
2/16/2025	Upper Providence/Bortondale	2673442	1930598	11	Project-C-Hours-Pump Truck-OT	\$291.68		\$3,208.48	6560006718
							Pump Station Total	\$5,006.48	
Upper Prov/Braves Trail									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/16/2025	Upper Providence/Braves Trail	2673442	1930600	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Respond to power failure during heavy wind event.	\$157.82	6588182132
							Pump Station Total	\$157.82	
Upper Prov/Rosetree Estates Upper									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/16/2025	Upper Providence/Rosetree Upper	2673442	1930605	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Respond to a high water alarm during heavy wind event. Station maintaining upon arrival. Observed proper operation before departure	\$157.82	6588182130
							Pump Station Total	\$157.82	
Upper Prov/Rosetree Estates Lower									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/16/2025	Upper Providence/Rosetree Lower	2673442	1930603	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Respond to a high water alarm during heavy wind event. Station maintaining upon arrival. Observed proper operation before departure	\$157.82	6588182129
							Pump Station Total	\$157.82	
Upper Prov./Rose Tree Park									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/3/2025	Upper Providence/Rose Tree Park	2673442	1930608	2	Project-C-Mechanic Foreman	\$105.21	Installed new Transducer	\$210.42	6588181241
2/3/2025	Upper Providence/Rose Tree Park	2673442	1930608	1	Project-Materials	\$1,293.43	Transducer	\$1,293.43	6588181241
2/3/2025	Upper Providence/Rose Tree Park	2673442	1930608	2	Project-C-Mechanic	\$97.54	Installed new Transducer	\$195.08	6588181242
							Pump Station Total	\$1,698.93	
Upper Prov/Valley View									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/7/2025	Upper Providence/Valley View	2673442	1930609	1	Project-C-Hours-Mechanic	\$97.54	Responded to an emergency call of station overflowing. Upon arrival observed the station was overflowing at D box due to influent pipe being blocked by grease and rags. Cleared influent pipe.	\$97.54	6588181472

2/7/2025	Upper Providence/Valley View	2673442	1930609	3	Project-C-Hours-Foreman-Mechanic	\$105.21	Returned to site with vacuum truck to clean site after station overflowed.	\$315.63	6588181473
2/7/2025	Upper Providence/Valley View	2673442	1930609	5	Project-C-Hours-Pump Truck	\$194.45	Returned to site with vacuum truck to clean site after station overflowed.	\$972.25	6560006643
2/7/2025	Upper Providence/Valley View	2673442	1930609	2000	Project-C-Disposal-Liquid (Gal)	\$0.08	Disposed of 2000 gallons to Delcora	\$160.00	6560006643
							Pump Station Total	\$1,545.42	

Upper Prov./Winters Street									
Service Date:	Location	Cust#	Jobsite#	Hours	Line item	Price per hour	Tech notes:	Total per WO	WO#
2/13/2025	Upper Providence/Winter Street	2673442	1930611	4	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Responded to a power failure alarm. Power was restored upon arrival. Observed proper operation before departure.	\$631.28	6588181800
2/16/2025	Upper Providence/Winter Street	2673442	1930611	1	Project-C-Hours-Foreman-Mechanic-OT	\$157.82	Respond to power failure during heavy wind event. Called outage into PECO	\$157.82	6588182131
							Pump Station Total	\$789.10	