



February 2025

Upper Providence Township Sewer Authority
Attention: Ms. Pat Hall
935 N. Providence Road
Media, PA 19063

RE: Sanitary Sewer Operations Maintenance Supervisors Report- February 2025

Operational Status of the facilities & General Pump Station Status

KBX Golden performed the following general pump station repairs and observations:

October- General pump station repairs

General:

- 2/6/25-Attempted to flush low pressure force main at the Rose Tree Park pump station. On site with township representative Tried flushing the line from two different locations. Unsuccessful. Will need to return.
- 2/7/25-Jetted low pressure force main to clear blockage located at East Rose Tree Road.

Bortondale Pump Station:

- 2/16/25-Respond to power failure during heavy wind event. Called in a Vacuum truck to help maintain the station. Called power failure into Peco.

Braves Trail Pump Station:

- 2/16/25-Respond to power failure during heavy wind event.

Letitia Lane Pump Station:

- Routine Maintenance.

Media Station Pump Station:

- Routine Maintenance.

Rose Tree Lower Pump Station

- 2/16/25-Respond to a high-water alarm during heavy wind event. Station maintained upon arrival. Observed proper operation before departure

Rose Tree Upper

- 2/16/25- Respond to a high-water alarm during heavy wind event. Station maintained upon arrival. Observed proper operation before departure

Rose Tree Park:

- 2/3/25-Installed new Transducer

Toft Woods Pump Station:

- Routine Maintenance.

Valley View Pump Station

- 2/7/25-Responded to an emergency call of station overflowing. Upon arrival observed the station was overflowing at D box due to influent pipe being blocked by grease and rags. Cleared influent pipe.
- 2/7/25-Returned to site with vacuum truck to clean site after station overflowed.

Winter Street

- 2/13/25-Responded to a power failure alarm. Power was restored upon arrival. Observed proper operation before departure.
- 2/16/25-Respond to power failure during heavy wind event. Called outage into PECO

